CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

NABL - Accredited Laboratory as per ISO / IEC-17025 :2005

T-2377

Job No.: CTCE/BBMP/W.No.12/KMR/CSR-04/002p/CEMENT/2016-17 Date: 04.04.2016

TEST REPORT ON CEMENT

* CUSTOMER	:	**Asst. Executive Engineer,** Shettyhalli Sub Division, BBMP, Bangalore.
*AGENCY	:	**Mr. K.M. Ravi** No. 74, 3rd Cross, 2nd Stage, Nagarabhavi, Bangalore.
*NAME OF THE WORK	:	Construction of culverts at Chikkasandra, Medarahalli & Kammagondanahalli in different locations in Ward No. 12 in Shettyhalli Sub Division, BBMP, Bangalore.
REFERENCE	:	EE/DD/WO/406/2014-15 Dated: 31.03.2015
SAMPLE ID	:	Cement
SAMPLE RECEIVED ON	:	02.04.2016
PERIOD OF TESTING	:	02.04.2016 to 04.04.2016

The results of the tests conducted on the cement sample are as follows:

Sl. No	Descriptions	Test Method as per IS	Test Result	Requirements as per IS: 8112-2013
1	Standard Consistency	IS-4031 (Part -4) 1988(RA-2009)	28.50 %	-
2	a) Initial Setting Time	IS-4031 (Part -5) 1988(RA-2009)	185 Minutes	Not Less than 30 Minutes
	b) Final Setting Time	IS-4031 (Part -5) 1988(RA-2009)	460 Minutes	Not More than 600 Minutes
3	Soundness by Le Chartlier Method	IS-4031 (Part-3) 1988(RA-2009)	1 mm	Not more than 10mm

*Information is furnished by the Customer/Representative.

Civil-Tech Consultants Bangalore Engineers

Note:

⇒ The report shall not be reproduced, except in full, without the written approval of the laboratory.

⇒ The results indicated above are based on the tests carried out on the samples received in the laboratory.

⇒ Any Query regarding the report must be reported within 30 days from the date of testing.

****

VISHWANATH .C
Quality Manager

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.
Tele Fax : 23223227, Website : www.civiltechconsultants.com
E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com

Scanned by CamScanner

CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

NABL - Accredited Laboratory as per ISO / IEC-17025 :2005

T-2377

Job No.: CTCE/BBMP/W.No.12/KMR/CSR-04/002p/SAND-Gradation/2016-17 : 04.04.2016

TEST REPORT ON DETERMINATION GRADATION OF FINE AGGREGATES

* Customer	: **Asst. Executive Engineer,** Shettyhalli Sub Division, BBMP, Bangalore.
* Agency	: **Mr. K.M. Ravi** No. 74, 3rd Cross, 2nd Stage, Nagarabhavi, Bangalore.
* Name of Work	: Construction of culverts at Chikkasandra, Medarahalli & Kammagondanahalli in different locations in Ward No. 12 in Shettyhalli Sub Division, BBMP, Bangalore.
Reference	: EE/DD/WO/406/2014-15 Dated: 31.03.2015
Technical Reference	: IS : 2386 Part 1 - 1963 RA-2007
Sample ID	: Fine Aggregates
Sample Received on	: 02.04.2016
Date of Testing	: 04.04.2016

Total Wt. of Aggregates in gms **1000**

Is Sieve Size in mm	Cumulative Weight Passing in %	Spec.Limits as per IS 383-1970 (RA- 2007)			
		Zone-I	Zone-II	Zone-III	Zone-IV
10	100	100	100	100	100
4.75	92.86	90-100	90-100	90-100	95-100
2.36	77.13	60-95	75-100	85-100	95-100
1.18	49.67	30-70	55-90	75-100	90-100
600 Micron	20.02	15-34	35-59	60-79	80-100
300 Micron	8.39	5-20	8-30	12-40	15-50
150 Micron	3.01	0-10	0-10	0-10	0-15

* Information is furnished by the Customer/Representative

Remarks : This sample is under Zone-I specific limits.

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

****

VISHWANATH .C
Quality Manager

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.
Tele Fax : 23223227, Website : www.civiltechconsultants.com
E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com

Scanned by CamScanner

CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

NABL - Accredited Laboratory as per ISO / IEC-17025 :2005

T-2377

Job No.: CTCE/BBMP/W.No.12/KMR/CSR-04/002p/CUBE/2016-17

23.05.2016

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

*** Customer** : **Asst. Executive Engineer,** Shettyhalli Sub Division, BBMP, Bangalore.

*** Agency** : **Mr. K.M. Ravi**
No. 74, 3rd Cross, 2nd Stage, Nagarabhavi, Bangalore.

*** Name of the work** : Construction of culverts at Chikkasandra, Medarahalli & Kammagondanahalli in different locations in Ward No. 12 in Shettyhalli Sub Division, BBMP, Bangalore.

*** Reference** : EE/DD/WO/406/2014-15 Dated: 31.03.2015



*** Sample ID** : Culvert Deck Slab Concrete

Size of cubes : 150mmx150mmx150mm

Cross Sectional Area : 22500 mm^2

Technical Reference : IS: 516-1959 (Reaffirmed 2008)

*** Grade of Concrete** : M_{20}

Compressive Strength as on : 28^{th} day

Sample Received on : 23.05.2016

Sl.No.	* Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	25.04.2016	23.05.2016	8.125	486.9	21.64
2	25.04.2016	23.05.2016	8.211	498.6	22.16
3	25.04.2016	23.05.2016	8.169	516.4	22.95

* Information is furnished by the Customer/Representative

Civil-Tech Consultants & Engineers Bangalore

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

****

VISHWANATH .C
Quality Manager

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.
Tele Fax : 23223227, Website : www.civiltechconsultants.com
E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com

Scanned by CamScanner

CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

NABL - Accredited Laboratory as per ISO / IEC-17025 :2005

T-2377

Job No.: CTCE/BBMP/W.No.12/KMR/CSR-04/002p/CUBE/2016-17 25.05.2016

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

*** Customer** : **Asst. Executive Engineer,** Shettyhalli Sub Division, BBMP, Bangalore.

*** Agency** : **Mr. K.M. Ravi**
No. 74, 3rd Cross, 2nd Stage, Nagarabhavi, Bangalore.

*** Name of the work** : Construction of culverts at Chikkasandra, Medarahalli & Kammagondanahalli in different locations in Ward No. 12 in Shettyhalli Sub Division, BBMP, Bangalore.

*** Reference** : EE/DD/WO/406/2014-15 Dated: 31.03.2015



*** Sample ID** : Culvert Deck Slab Concrete

Size of cubes : 150mmx150mmx150mm

Cross Sectional Area : 22500 mm^2

Technical Reference : IS: 516-1959 (Reaffirmed 2008)

*** Grade of Concrete** : M_{20}

Compressive Strength as on : 28^{th} day

Sample Received on : 25.05.2016

Sl.No.	* Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	27.04.2016	25.05.2016	8.215	478.9	21.28
2	27.04.2016	25.05.2016	8.326	489.6	21.76
3	27.04.2016	25.05.2016	8.287	501.7	22.30

* Information is furnished by the Customer/Representative

Civil-Tech Consultants & Engineers Bangalore

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

****

VISHWANATH .C
Quality Manager

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.
Tele Fax : 23223227, Website : www.civiltechconsultants.com
E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com

Scanned by CamScanner